



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYB091398

This is to certify that the product

Limit Switch

manufactured by

NUTORK CORP.

(Address: No.158, Lane 1888, Daye Road, Feng-Xian Area, Shanghai, China)

which model is

NTS-E *a*

Ex marking

Ex d II B T6

product standard

Q/ HIC 1016 -2005

drawing number

NTS-E 01

has been inspected and certified by NEPSI, and that it conforms
to GB 3836.1-2000 GB 3836.2-2000

This Approval shall remain in force until

2014.6.18

Remarks

1. Special conditions for safe use specified in the manual of the product .
2. In the model: *a* indicates the quantity of different microswitches. The code of *a* can be 10, 11, 12, 13 or 14 .

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2009.6.18



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel:0086 21 64368180
Fax:0086 21 64844580